



State of Utah

Department of  
Environmental Quality

Dianne R. Nielson, Ph.D.  
*Executive Director*

DIVISION OF WATER QUALITY  
Walter L. Baker, P.E.  
*Acting Director*

**Water Quality Board**  
Ray M. Child, *Chair*  
Douglas E. Thompson, *Vice-Chair*  
Robert G. Adams  
David F. Echols  
Neil K. Kochenour  
Dianne R. Nielson  
Jay Ivan Olsen  
Joe Piccolo  
Ronald C. Sims  
J. Ann Wechsler  
Walter L. Baker  
*Acting Executive Secretary*

OLENE S. WALKER  
*Governor*

GAYLE F. McKEACHNIE  
*Lieutenant Governor*

August 5, 2004

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY

PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO SOLICIT PUBLIC COMMENTS REGARDING THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-104 AND 107, UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO UPDES PERMIT AND THE STATEMENT OF BASIS. (INCLUDING THE TOTAL MAXIMUM DAILY LOADS (TMDL'S), IF APPLICABLE, AS PER SECTION 303 (d) OF THE FEDERAL CLEAN WATER ACT (CWA).

**PERMIT INFORMATION**

|                    |   |
|--------------------|---|
| PERMITTEE NAME:    | Bear River City Corporation             |
| MAILING ADDRESS:   | P.O. Box 160                            |
| TELEPHONE NUMBER:  | (435) 279-9047 or (435) 279-8452 (Cell) |
| FACILITY LOCATION: | Northwest of Ogden in Box Elder County  |
| UPDES PERMIT NO.:  | UT0020311                               |

**BACKGROUND**

Bear River City Lagoon System consists of a comminutor and bar screen, followed by a six cell facultative wastewater lagoon system that discharges directly to the Malad River at approximately .20 MGD.

**PUBLIC COMMENTS**

Public comments are invited any time prior to September 12, 2004. Comments may be directed to the Department of Environmental Quality, Division of Water Quality, 288 North 1460 West, P.O. Box 144870, Salt Lake City, Utah 84114-4870. All comments received prior to September 12, 2004 will be considered in the formulation of final determinations to be imposed in the renewal permit. A public hearing will be held if response to this Notice indicates significant public interest. A public hearing may be held if written requests are received within the first 15 days of this public comment period that demonstrate significant public interest and substantive issues exist to warrant holding a hearing.

**FURTHER INFORMATION**

Additional information may be obtained upon request by calling Mark Schmitz at (801) 538-6097 or by writing the aforementioned address. All information appropriate to this permit renewal is available for review at the Division of Water Quality, 288 North 1460 West, Salt Lake City, Utah.

